

Compressed Gas and Cylinders Checklist

- Are cylinders with water-weight capacity over 30 pounds equipped with means for connecting a valve protector or device, or with a collar or recess to protect the valve?
- Are cylinders legibly marked to clearly identify the gas contained?
- Are compressed gas cylinders located or stored in areas where they will not be damaged by passing or falling objects or be subject to tampering by unauthorized persons?
- Are cylinders containing liquefied fuel gas stored or transported in a position so that the safety relief device is always in direct contact with the vapor space in the cylinder?
- Are valve protectors always placed on cylinders when the cylinders are not in use or connected for use?
- Are all valves closed off before a cylinder is moved, when the cylinder is empty, and at the completion of each job?
- Are low-pressure fuel-gas cylinders checked periodically for corrosion, general distortion, cracks, or any other defect that might indicate a weakness or render them unfit for service?
- Does the periodic check of low-pressure fuel-gas cylinders include a close inspection of the bottom of each cylinder?

